

01-29-21 15:14 FROM- WYOM CTY ENVIR. HEAL 5857868167

T-251 P0003/0008 F-124

RECEIVED

JAN 26 2021

Wyoming County Health Dept.
Silver Springs, New York



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1A1173

Client Sample ID: MGLDF	Collected By: TB-Client
Sample Matrix: Drinking Water	Collection Date: 01/06/2021 6:22
Lab Sample ID: J1A1173-06	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0095	0.015 AL	0.0010	mg/L		01/25/21 1127	01/25/21 1144	DLO

Client Sample ID: NRS	Collected By: TB-Client
Sample Matrix: Drinking Water	Collection Date: 01/06/2021 6:18
Lab Sample ID: J1A1173-06	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0086	0.015 AL	0.0010	mg/L		01/25/21 1127	01/25/21 1146	DLO

Client Sample ID: HR 111 SA	Collected By: TB-Client
Sample Matrix: Drinking Water	Collection Date: 01/06/2021 6:15
Lab Sample ID: J1A1173-07	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0102	0.015 AL	0.0102	mg/L	D	01/25/21 1127	01/26/21 1233	DLO

Client Sample ID: HR 309 SR	Collected By: TB-Client
Sample Matrix: Drinking Water	Collection Date: 01/06/2021 6:11
Lab Sample ID: J1A1173-08	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0029	0.015 AL	0.0010	mg/L		01/25/21 1127	01/25/21 1153	DLO

01-29-21 15:15 FROM- WYOM CTY ENVIR. HEAL 5857868167

T-251 P0004/0008 F-124



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1A1173

RECEIVED

JAN 26 2021

Wyoming County Health Dept.
Silver Springs, New York

Client Sample ID:	HR 309 SL	Collected By:	TB-Client
Sample Matrix:	Drinking Water	Collection Date:	01/06/2021 6:11
Lab Sample ID:	J1A1173-09		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0019	0.015 AL	0.0010	mg/L		01/25/21 1127	01/25/21 1155	DLO

Client Sample ID:	MR 150 D	Collected By:	TB-Client
Sample Matrix:	Drinking Water	Collection Date:	01/06/2021 6:20
Lab Sample ID:	J1A1173-10		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0155	0.015 AL	0.0010	mg/L		01/25/21 1127	01/25/21 1157	DLO

Client Sample ID:	MR 150 C	Collected By:	TB-Client
Sample Matrix:	Drinking Water	Collection Date:	01/06/2021 6:20
Lab Sample ID:	J1A1173-11		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0104	0.015 AL	0.0010	mg/L		01/25/21 1127	01/25/21 1159	DLO

Client Sample ID:	MR 150 W	Collected By:	TB-Client
Sample Matrix:	Drinking Water	Collection Date:	01/06/2021 6:21
Lab Sample ID:	J1A1173-12		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0091	0.015 AL	0.0010	mg/L		01/25/21 1127	01/25/21 1203	DLO

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

01-29-21 15:15 FROM- WYOM CTY ENVIR. HEAL 5857868167

T-251 P0005/0008 F-124



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1A1173

RECEIVED

JAN 26 2021

Wyoming County Health Dept.
Silver Springs, New York

Client Sample ID: HR 215 S

Sample Matrix: Drinking Water

Lab Sample ID: J1A1173-13

Collected By: TB-Client

Collection Date: 01/06/2021 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0117	0.015 AL	0.0010	mg/L		01/25/21 1127	01/25/21 1204	DLO

Client Sample ID: HR 215 BC

Sample Matrix: Drinking Water

Lab Sample ID: J1A1173-14

Collected By: TB-Client

Collection Date: 01/06/2021 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0078	0.015 AL	0.0010	mg/L		01/25/21 1127	01/25/21 1206	DLO

Client Sample ID: HR 218 FI

Sample Matrix: Drinking Water

Lab Sample ID: J1A1173-15

Collected By: TB-Client

Collection Date: 01/06/2021 6:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.628	0.015 AL	0.0010	mg/L		01/25/21 1127	01/25/21 1208	DLO

Client Sample ID: HR 219 I

Sample Matrix: Drinking Water

Lab Sample ID: J1A1173-16

Collected By: TB-Client

Collection Date: 01/06/2021 6:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	2.74	0.015 AL	0.0102	mg/L	D	01/25/21 1127	01/26/21 1242	DLO

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Microbac Laboratories, Inc.

3921 Buck Dr. | Cortland, NY 13045 | 607-763-3403 p | www.microbac.com



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1A1173

RECEIVED

JAN 26 2021

Wyoming County Health Dept.
Silver Springs, New York

Definitions

- AL: US EPA Action Level
- D: The sample was diluted due to matrix interference.
- MCL: US EPA Maximum Contaminant Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville
11549

New York State Department of Health

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.

Reviewed and Approved By:

Renee Lantz
Customer Relationship Specialist
Reported: 01/26/2021 18:14

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com